


FACILITY SCORECARD: Letford Elementary School

0.70 SCI | REPLACE

NEEDS: \$8,859,515.00

Age: Constructed in 1957 with Additions in 1976, 1984, and 1996
Modular Classrooms: Four
Current Enrollment: 504 Students (February 6, 2019)
Program Capacity: 624 Students (Not Including Modular Classrooms)



The System Condition Index (SCI) is the cost to repair system deficiencies divided by the cost of system replacement. In general, once the cost of repairs exceeds 50% to 60% of the cost of replacement, replacement is recommended. CDE cost estimates are referenced as a baseline; Capital Renewal Estimates solicited by Weld RE-5J from Construction Firms significantly exceed CDE estimates. For more information, visit www.weldre5j.k12.co.us.